

CERTIFICATE OF COMPLIANCE

Certificate Number 20121115-E161818
Report Reference E161818-19971230
Issue Date 2012-NOVEMBER-15

Issued to: R STAHL SCHALTGERAETE GMBH
AM BAHNHOF 30
74638 WALDENBURG GERMANY

**This is to certify that
representative samples of**

AUDIBLE-SIGNAL APPLIANCES FOR USE IN
HAZARDOUS LOCATIONS, AUDIBLE-SIGNAL
APPLIANCES FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS


See Addendum page for model

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum page for standard.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20121115-E161818
Report Reference E161818-19971230
Issue Date 2012-NOVEMBER-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Explosion proof audible alarm, Model YA60, followed by .B, followed by .D/.F/.L/ or .N, followed by .UL;
explosion proof audible/visual alarm, Model YL60, followed by .B, followed by .D/.F/.L/ or .N,
followed by 50, followed by .A, .B, .C, .G, .O, .R, or .Y, followed by .UL for use in Class I,
Div. 1, Groups B, C and D; Div. 2, Groups B, C, and D; Hazardous Locations.
Class I, Zone 1 AEx d IIB + H₂ and Ex d IIB + H₂.

Flameproof Audible Alarm, Model YA60 followed by .B; followed by .D/.F/.L/ or .N; followed by .UL. Flameproof
Audible/Visual Alarm, Model YL60 followed by .B, followed by .D/.F/.L/ or .N; followed by 50; followed by .A, .B, .C,
.G, .O, .R or .Y; followed by .UL

Class I, Zone 1 AEx d IIB; Ex d IIB

Flameproof Audible Alarm, Model YA60 followed by .C; followed by .D/.F/.L/ or .N; followed by .UL. Flameproof
Audible/Visual Alarm, Model YL60 followed by .C, followed by .D/.F/.L/ or .N; followed by 50; followed by .A, .B, .C,
.G, .O, .R or .Y; followed by .UL.

Standard(s) for Safety

UL 1203-Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations, UL
60079-0-Electrical Apparatus for
Explosive Gas Atmospheres – Part 0: General Requirements, UL 60079-1-Electrical Apparatus for Explosive
Gas Atmospheres – Part 1: Flameproof Enclosures “d”, CAN/CSA C22.2 No. 25-1966-Enclosures for Use in
Class II Groups E, F, and G Hazardous Locations, CAN/CSA C22.2 No. 30-M1986-Rev. 1988-11, Explosion-
Proof Enclosures for Use in Class I Hazardous Locations, CAN/CSA C22.2 No. 213-M1987-Non-incendive
Electrical Equipment for Use in Class I, Division 2 Hazardous Locations, CAN/CSA-C22.2 No. E60079-0:07-
Electrical apparatus for explosive gas atmospheres – Part 0: General requirements



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

